



ISO5149

Draft

Standard

review

Ref: ISO5149 standard Rev 1

Jonathan Fryer



Part 1

	Item	ISECO comment	Action/Outcome
1	Table A1 Charge Limits based on toxicity & Table A2 charge Limits based on Flammability	<p>E.g. test against a cold store using ammonia refrigerant with plant in plant room and coils in Space.</p> <p>I.e. Occupancy Type C Class 11 location R717 is a B2L Refrigerant</p> <p>Personal Density less than 1 per 10 sqm</p> <p>Personal Density more than 1 per 10sqm</p>	<p>No charge Limit = ok</p> <p>Charge limit for Class 11 = 25kg</p> <p>This will stop use of direct ammonia large charge in boning rooms etc which is probably good practice anyway.</p>
2	Table A1 Charge Limits based on toxicity & Table A2 charge Limits based on Flammability	<p>E.g. Ammonia to chilled water through a single Plate heat exchanger serving an office building</p> <p>I.e. Occupancy Type B Class 111 Location B2L Refrigerant</p>	<p>No charge limit = ok but see notes on Parts 2 & 3 for large ammonia systems and also part 1 cl 8.9 (refer below)</p>
3	Table A1 Charge Limits based on toxicity & Table A2 charge Limits based on Flammability	<p>E.g. CO2 DX transcritical serving a 900 sqm supermarket with CO2 Dx in multideck cases in store location</p> <p>Co2 is an A1 Refrigerant so Table A2 (flammability) does not apply. Supermarket = Type A occupancy</p> <p>Class 11 location (i.e. plant in open air or machinery room ,coils in Space</p>	<p>Toxicity Limit x Room volume = 0.1 kg/cum * 900sqm x2.7m = 243 kg charge limit for Co2</p> <p>This should be ok, we are using significantly less typically.</p> <p>Note back of house rooms occupancy Type C no charge limit except Part 3 CL 8.1 needs safety alarms if Practical Limit is exceeded = ok</p>



4	Table A1 Charge Limits based on toxicity & Table A2 charge Limits based on Flammability	<p>E.g. Small R290 system sealed system located in shop store area serving multideck cases etc above ground</p> <p>R290 is A3 Refrigerant</p> <p>Type A occupancy</p> <p>Class I location of plant</p>	<p>Table A2 20% x LFL x Room Vol and not more than 1.5kg</p> <p>Does this mean we can exceed the 150 g limit used in AS/NZS 60335</p>
5	<p>CL 8.9 Heat transfer fluid</p> <p>CL 8.9 Flash point - shall not be less than 55oC</p>	<p>Does this apply to use of ethanol water mixtures as secondary refrigerants in Wineries? To date so long as alcohol content was under 24% it was not considered a flammable liquid under the Australian Dangerous Goods regs - The ethanol water mix has an open cup fire point of 68C and does not generate enough heat to sustain combustion</p>	<p>Assume no issues with use of secondary refrigerants such as Alcohol LF ec with less than 24% alcohol?</p>



Part 2

	Item	ISECO comment	Action/Outcome
1	Maximum allowable pressure (PS) Cl 5.2.2.1	<p>There are two methods permitted to be used to determine the design pressures/ temperatures</p> <p>Our concern is that this will be open to interpretation unless it's clear what "regional Data " is permissible. It was better when DA-9 critical 0800-1800 was specified - not certain what the reference to IEC 60721 is.</p>	<p>Could be some increases in the traditionally used design pressures if Table 2 is used e.g. Melbourne site with evaporative condenser system would have 43oC sat refriger pressure</p> <p>(Used to be 38.2)</p>
2	Protection of the Secondary cooling System Cl 5.2.9.5	This requires automatic air/ refrigerant separators on the secondary circuit and or automatic detection in the secondary circuit if primary refrigerant is soluble (e.g. ammonia /water?)	This is new; we have not had any loss or safety issues with ammonia /glycol/ ammonia water systems that have appropriate antifreeze and over pressure protection to date.
3	Appendix B (Normative) Additional requirements for refrigeration systems with ammonia	If refrigerant charge is over 4,500kg - requires a functionally remote controlled shut off in the liquid line	New - probably good practice for larger systems



Part 3

	Item	ISECO comment	Action/Outcome
1	<p>Machinery rooms Clause 5.12.3 Walls floor & ceiling Walls floor & ceiling between the inside of the building and the machinery room shall have minimum 1 hour fire rating</p> <p>Also Doors require 1 hour fire rating (which we did previously have)</p>	This was not specifically stated before	Good practice
2	<p>Machinery Rooms Clause 5.14.2.2 - Specific requirements for emergency Washing if R717 is used - eyewash & shower are required</p>	This was not previously a normative requirement	Good Practice
3	<p>Fire Sprinkler Systems Claus 5.14.2.3</p> <p>Fire sprinkler systems shall not be permitted in machinery rooms with R717 systems of more than 200kg charge</p>	This is new and will be at odds with some property insurers requirements e.g. FM and maybe Australian fire sprinkler standards	May need to use a flow switch in the fire sprinkler system to isolate electrical power supplies if this is the concern?